



Compliance Statement

Screened Class EA / Category 6A

ISO/IEC, EN & ANSI/TIA

Two Connector Permanent Link

**Maxeta AS
Amtmand Aallsgate 89,
3716 Skien, Norway**

Compliance Statement No. 0473-3P-1231197

This type of Class EA / Category 6A Screened Two Connector Permanent Link has been tested by 3P Third Party Testing. The testing has shown compliance with the Class EA electrical performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, edition 1.0 of ISO/IEC 11801-2:2017, CENELEC EN 50173-1:2018 and the Category 6A electrical performance requirements of ANSI/TIA-568.2-D:2018. The Compliance Statement is valid for the actually tested permanent link samples, consisting of the listed components. The tested permanent link is part of a 3P maintenance programme, with continuous verification of the electrical performance. The Compliance Statement is valid until 7 May 2026.

Cables:	<i>Horizontal Cable 15 m - 90 m, P/N 77780500</i>
	<i>Qualification Status: Manufacturer verified</i>
Conn. Hardware:	<i>Modular Jack, P/N 30070</i>
	<i>Qualification Status: Manufacturer verified</i>

Hoersholm, 7 November 2023


Peter Freiberg Kaas
Test Responsible

3P Third Party Testing ApS
Agern Alle 3
2970 Hørsholm
Denmark

<https://www.3ptest.dk/>

Hoersholm, 7 November 2023


Jens Rytter Petersen
General Manager